

EMC TEST REPORT

For

Shanghai Panelmate Electronics Co., Ltd.

Industrial Operation Panel PC

Test Model: IPC3619-3K-TRUMPF

Prepared for	: Shanghai Panelmate Electronics Co., Ltd.
Address	: Building 18th, No.177 Fulian 2nd Rd. Baoshan District, Shanghai, 201906
Prepared by	: Shenzhen LCS Compliance Testing Laboratory Ltd.
Address	: 101, 201 Building A and 301 Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Baoan District, Shenzhen, Guangdong, China
Tel	: (+86)755-82591330
Fax	: (+86)755-82591332
Web	: www.LCS-cert.com
Mail	: webmaster@LCS-cert.com
Date of receipt of test sample	: January 08, 2022
Number of tested samples	: 1
Sample No.	: 211231033A
Date of Test	: January 08, 2022 ~ February 24, 2022
Date of Report	: February 25, 2022



Scan code to check authenticity



EMC TEST REPORT EN IEC 61000-6-3:2021 Electromagnetic Compatibility (EMC) - Part 6 - 3 : Generic Standards – Emission standard for equipment in residential environments EN IEC 61000-6-2:2019 Electromagnetic compatibility (EMC) - Part 6-2: Generic standards - Immunity standard for industrial environments	
Report Reference No.:	LCS211231033AE
Date Of Issue	February 25, 2022
Testing Laboratory Name:	Shenzhen LCS Compliance Testing Laboratory Ltd.
Address.....:	101, 201 Building A and 301 Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street, Baoan District, Shenzhen, Guangdong, China
Testing Location/ Procedure ..:	Full application of Harmonised standards ☒ Partial application of Harmonised standards ☐ Other standard testing method ☐
Applicant's Name.....:	Shanghai Panelmate Electronics Co., Ltd.
Address.....:	Building 18th, No.177 Fulian 2nd Rd. Baoshan District, Shanghai, 201906
Test specification:	
Standard	EN IEC 61000-6-3:2021 EN IEC 61000-6-2:2019
Test Report Form No.....:	LCSEMC-1.0
TRF Originator	Shenzhen LCS Compliance Testing Laboratory Ltd.
Master TRF	Dated 2011-03
SHENZHEN LCS COMPLIANCE TESTING LABORATORY LTD. All rights reserved. This publication may be reproduced in whole or in part for non-commercial purposes as long as the SHENZHEN LCS COMPLIANCE TESTING LABORATORY LTD. is acknowledged as copyright owner and source of the material. SHENZHEN LCS COMPLIANCE TESTING LABORATORY LTD. takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
Test Item Description.....:	Industrial Operation Panel PC
Trade Mark.....:	Panelmate
Test Model	IPC3619-3K-TRUMPF
Ratings.....:	DC 24V, 2A
Result	Positive

Compiled by:

Cindy Nie

Cindy Nie/ File administrators

Supervised by:

Baron Wen

Baron Wen/Technique principal

Approved by:

Gavin Liang/ Manager



EMC -- TEST REPORT

Test Report No. : LCS211231033AEFebruary 25, 2022
Date of issue

Test Model..... : IPC3619-3K-TRUMPF

EUT..... : Industrial Operation Panel PC

Applicant..... : Shanghai Panelmate Electronics Co., Ltd.Address..... : Building 18th, No.177 Fulian 2nd Rd. Baoshan District,
Shanghai, 201906

Telephone..... : /

Fax..... : /

Manufacturer..... : Shanghai Panelmate Electronics Co., Ltd.Address..... : Building 18th, No.177 Fulian 2nd Rd. Baoshan District,
Shanghai, 201906

Telephone..... : /

Fax..... : /

Factory..... : Shanghai Panelmate Electronics Co., Ltd.Address..... : Building 18th, No.177 Fulian 2nd Rd. Baoshan District,
Shanghai, 201906

Telephone..... : /

Fax..... : /

Test Result according to the standards on page 6: **Positive**

The test report merely corresponds to the test sample.

It is not permitted to copy extracts of these test result without the written permission of the test laboratory.



Revision History

Revision	Issue Date	Revision Content	Revised By
000	February 25, 2022	Initial Issue	/



TABLE OF CONTENT

Test Report Description	Page
1. SUMMARY OF STANDARDS AND RESULTS	6
1.1. Description of Standards and Results	6
1.2. Description of Performance Criteria.....	7
2. GENERAL INFORMATION	8
2.1. Description of Device (EUT).....	8
2.2. Description of Test Facility	8
2.3. Statement of the Measurement Uncertainty	8
2.4. Measurement Uncertainty	9
3. MEASURING DEVICES AND TEST EQUIPMENT	10
4. TEST RESULTS	12
4.1. Power Line Conducted Emission Measurement.....	12
4.2. Radiated Emission Measurement	16
4.3. ElectrostaTic Discharge Immunity Test.....	20
4.4. RF Field Strength Susceptibility Test	23
4.5. Electrical Fast Transient/Burst Immunity Test.....	26
4.6. Surge Immunity Test	29
4.7. Injected Currents Susceptibility Test	32
4.8. Magnetic Field Susceptibility Test.....	35
5. PHOTOGRAPHS OF TEST SETUP	38
6. EXTERNAL AND INTERNAL PHOTOS OF THE EUT.....	42



1. SUMMARY OF STANDARDS AND RESULTS

1.1. Description of Standards and Results

The EUT have been tested according to the applicable standards as referenced below.

EMISSION (EN IEC 61000-6-3:2021)			
Description of Test Item	Standard	Limits	Results
Conducted disturbance at mains terminals	EN 55032:2015+A11:2020	Class A	PASS
Conducted disturbance at telecommunication port	EN 55032:2015+A11:2020	Class A	N/A
Radiated disturbance	EN 55032:2015+A11:2020	Class A	PASS
Harmonic current emissions	EN IEC 61000-3-2:2019	Class A	N/A
Voltage fluctuations & flicker	EN 61000-3-3: 2013+A1:2019	-----	N/A
IMMUNITY (EN IEC 61000-6-2:2019)			
Description of Test Item	Basic Standard	Performance Criteria	Results
Electrostatic discharge (ESD)	EN 61000-4-2: 2009	B	PASS
Radio-frequency, Continuous radiated disturbance	EN 61000-4-3: 2006+A2: 2010	A	PASS
Electrical fast transient (EFT)	EN 61000-4-4: 2012	B	PASS
Surge (Input d.c. power ports)	EN 61000-4-5: 2014+A1:2017	B	PASS
Surge (Telecommunication ports)		B	PASS
Radio-frequency, Continuous conducted disturbance	EN 61000-4-6: 2014+A1:2015	A	PASS
Power frequency magnetic field	EN 61000-4-8: 2010	A	PASS
Voltage dips, >95% reduction	EN IEC 61000-4-11:2020	B	N/A
Voltage dips, 30% reduction		C	N/A
Voltage interruptions		C	N/A
N/A is an abbreviation for Not Applicable.			

Test mode:		
Mode 1	Working	Record
***Note: All test modes were tested, but we only recorded the worst case in this report.		



1.2. Description of Performance Criteria

General Performance Criteria

Examples of functions defined by the manufacturer to be evaluated during testing include, but are not limited to, the following:

- essential operational modes and states;
- tests of all peripheral access (hard disks, floppy disks, printers, keyboard, mouse, etc.);
- quality of software execution;
- quality of data display and transmission;
- quality of speech transmission.

1.2.1. Performance criterion A

The equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed below a performance level specified by the manufacture when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.2. Performance criterion B

After the test, the equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed, after the application of the phenomena below a performance level specified by the manufacture, when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance.

During the test, degradation of performance is allowed. However, no change of operation state or stored data is allowed to persist after the test.

If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.3. Performance criterion C

Loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls by the user in accordance with the manufacture's instructions.

Functions, and/or information stored in non-volatile memory, or protected by a battery backup, shall not be lost.





2. GENERAL INFORMATION

2.1. Description of Device (EUT)

EUT : Industrial Operation Panel PC

Trade Mark : Panelmate

Test Model : IPC3619-3K-TRUMPF

Power Supply : DC 24V, 2A

EUT Clock Frequency : $\leq 108\text{MHz}$

2.2. Description of Test Facility

Site Description

EMC Lab. : NVLAP Accreditation Code is 600167-0.
FCC Designation Number is CN5024.
CAB identifier is CN0071.
CNAS Registration Number is L4595.

2.3. Statement of the Measurement Uncertainty

The data and results referenced in this document are true and accurate. The reader is cautioned that there may be errors within the calibration limits of the equipment and facilities. The measurement uncertainty was calculated for all measurements listed in this test report acc. To CISPR 16 – 4 “Specification for radio disturbance and immunity measuring apparatus and methods – Part 4: Uncertainty in EMC Measurements” and is documented in the LCS quality system acc. To DIN EN ISO/IEC 17025. Furthermore, component and process variability of devices similar to that tested may result in additional deviation. The manufacturer has the sole responsibility of continued compliance of the device.



2.4.Measurement Uncertainty

Test	Parameters	Expanded uncertainty (U _{lab})	Expanded uncertainty (U _{cispr})
Coucted Emission	Level accuracy (9kHz to 150kHz) (150kHz to 30MHz)	± 2.63 dB ± 2.35 dB	± 3.8 dB ± 3.4 dB
Power Disturbance	Level accuracynd (30MHz to 300MHz)	± 2.90 dB	± 4.5 dB
Electromagnetic Radiated Emission (3-loop)	Level accuracy (9kHz to 30MHz)	± 3.60 dB	± 3.3 dB
Radiated Emission	Level accuracy (9kHz to 30MHz)	± 3.68 dB	N/A
Radiated Emission	Level accuracy (30MHz to 1000MHz)	± 3.48 dB	± 5.3 dB
Radiated Emission	Level accuracy (above 1000MHz)	± 3.90 dB	± 5.2 dB
Voltage Fluctuations & Flicker	Voltage	$\pm 0.510\%$	N/A
EMF		$\pm 21.59\%$	N/A

- (1) Where relevant, the following measurement uncertainty levels have been estimated for tests performed on the apparatus.
- (2) The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor of $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.



3. MEASURING DEVICES AND TEST EQUIPMENT

LINE CONDUCTED EMISSION						
Item	Equipment	Manufacturer	Model No.	Serial No.	Cal Date	Due Date
1	EMI Test Software	EZ	EZ-EMC	/	N/A	N/A
2	EMI Test Receiver	R&S	ESR3	102312	2021-03-16	2022-03-15
3	Artificial Mains	R&S	ENV216	101119	2021-06-21	2022-06-20
4	Pulse Limiter	R&S	ESH3-Z2	102750-NB	2021-08-19	2022-08-18
5	Impedance Stabilization Network	TESEQ	ISN T800	45130	2021-11-16	2022-11-15

RADIATED DISTURBANCE						
Item	Equipment	Manufacturer	Model No.	Serial No.	Cal Date	Due Date
1	EMI Test Software	E3	E3-EMC	/	N/A	N/A
2	By-log Antenna	SCHWARZBECK	VULB9163	9163-470	2021-09-12	2024-09-11
3	Horn Antenna	SCHWARZBECK	BBHA 9120D	9120D-1925	2021-09-05	2024-09-04
4	EMI Test Receiver	R&S	ESR3	102311	2021-08-19	2022-08-18
5	Broadband Preamplifier	/	BP-01M18G	P190501	2021-06-21	2022-06-20

ELECTROSTATIC DISCHARGE						
Item	Equipment	Manufacturer	Model No.	Serial No.	Cal Date	Due Date
1	ESD Simulator	SCHLODER	SESD 230	604035	2021-07-28	2022-07-27

RF ELECTROMAGNETIC FIELD)						
Item	Equipment	Manufacturer	Model No.	Serial No.	Cal Date	Due Date
1	ESG Vector Signal Generator	Agilent	E4438C	MY42081396	2021-06-11	2022-06-10
2	RF POWER AMPLIFIER	OPHIR	5225R	1052	NCR	NCR
3	RF POWER AMPLIFIER	OPHIR	5273F	1019	NCR	NCR
4	Stacked Broadband Log Periodic Antenna	SCHWARZBEC K	STLP 9128	9128ES-145	NCR	NCR
5	Stacked Mikrowellen Log.-Per Antenna	SCHWARZBEC K	STLP 9149	9149-484	NCR	NCR
6	Electric field probe	Narda S.T.S./PMM	EP601	611WX80208	2021-06-29	2022-06-28
Note: NCR means no calibration requirement						

ELECTRICAL FAST TRANSIENT IMMUNITY						
Item	Equipment	Manufacturer	Model No.	Serial No.	Cal Date	Due Date
1	Immunity Simulative Generator	EM TEST	UCS500-M4	0101-34	2021-06-21	2022-06-20
2	Capacitive coupling clamp	3CTEST	EC0441098	EFTC	2021.06.21	2022.06.20

**SURGES, LINE TO LINE AND LINE TO GROUND**

Item	Equipment	Manufacturer	Model No.	Serial No.	Cal Date	Due Date
1	Immunity Simulative Generator	EM TEST	UCS500-M4	0101-34	2021-06-21	2022-06-20
2	Communication wave lightning generator	HTEC	181701	HTSG 70	2021.11.15	2022.11.14
3	Symmetrical data line coupling network	HTEC	182701	HCN 8	2021.11.15	2022.11.14
4	Data line decoupling network	HTEC	182702	HDEC 8	2021.11.15	2022.11.14

RF COMMON MODE

Item	Equipment	Manufacturer	Model No.	Serial No.	Cal Date	Due Date
1	Simulator	FRANKONIA	CIT-10/75	A126A1195	2021-08-19	2022-08-18
2	CDN	FRANKONIA	CDN-M2+M3	A2210177	2021-06-21	2022-06-20
3	6dB Attenuator	FRANKONIA	DAM25W	1172040	2021-06-21	2022-06-20
4	Electromagnetic coupling injection clamp	ZHINAN	14017	ZN23203	2021.06.25	2022.06.24

MAGNETIC FIELD SUSCEPTIBILITY TEST

Item	Equipment	Manufacturer	Model No.	Serial No.	Cal Date	Due Date
1	Power frequency mag-field generator System	EVERFINE	EMS61000-8K	906003	2021-06-21	2022-06-20


NCR --- No calibration requirement.



4. TEST RESULTS

4.1. Power Line Conducted Emission Measurement

4.1.1. Block Diagram of Test Setup



4.1.2. Test Standard

EN IEC 61000-6-3:2021 Class A

Power Line Conducted Emission Limits (Class A)		
Frequency (MHz)	Limit (dB μ V)	
	Quasi-peak Level	Average Level
0.15 ~ 0.50	79	66
0.50 ~ 30.00	73	60

NOTE1-The lower limit shall apply at the transition frequencies.
NOTE2-The limit decreases linearly with the logarithm of the frequency in the range 0.15MHz to 0.50MHz.

4.1.3. EUT Configuration on Test

The following equipments are installed on Power Line Conducted Emission Measurement to meet the EN 55032 requirement and operating regulations in a manner, which tends to maximize its emission characteristics in a normal application.

4.1.4. Operating Condition of EUT

4.1.4.1. Setup the EUT as shown on Section 4.1.1

4.1.4.2. Turn on the power of all equipments.

4.1.4.3. Let the EUT work in measuring Mode 1, Mode 2 and measure it.



4.1.5. Test Procedure

The EUT is put on the plane 0.8m high above the ground by insulating support and connected to the DC mains through Line Impedance Stability Network (L.I.S.N). This provided 50-ohm coupling impedance for the tested equipments. Both sides of DC line are investigated to find out the maximum conducted emission according to the EN 55032 regulations during conducted emission measurement.

The bandwidth of the field strength meter is set at 9kHz in 150kHz~30MHz.

The frequency range from 150kHz to 30MHz is investigated.

4.1.6. Test Results


PASS.

The test result please refer to the next page.






Test Model	IPC3619-3K-TRUMPF	Test Mode	Mode 1
Environmental Conditions	22.7°C, 53.7% RH	Test Engineer	Paul Xie
Pol.	Positive	Test Voltage	DC 24V



No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuV	Limit dBuV	Margin dB	Detector	Comment
1		0.1949	18.69	19.75	38.44	63.83	-25.39	QP	
2		0.2131	6.63	19.75	26.38	53.08	-26.70	AVG	
3		0.5594	21.79	19.78	41.57	56.00	-14.43	QP	
4	*	0.5594	17.82	19.78	37.60	46.00	-8.40	AVG	
5		1.4144	16.47	19.80	36.27	56.00	-19.73	QP	
6		1.4503	10.49	19.80	30.29	46.00	-15.71	AVG	
7		3.5746	14.86	19.88	34.74	56.00	-21.26	QP	
8		3.7096	9.33	19.88	29.21	46.00	-16.79	AVG	
9		5.4870	12.81	19.93	32.74	60.00	-27.26	QP	
10		5.6356	7.21	19.93	27.14	50.00	-22.86	AVG	
11		25.1701	12.71	20.62	33.33	60.00	-26.67	QP	
12		26.2364	-3.27	20.61	17.34	50.00	-32.66	AVG	



Test Model	IPC3619-3K-TRUMPF	Test Mode	Mode 1
Environmental Conditions	22.7°C, 53.7% RH	Test Engineer	Paul Xie
Pol.	Negative	Test Voltage	DC 24V




No.	Mk.	Freq. MHz	Reading Level dBuV	Correct Factor dB	Measure- ment dBuV	Limit dBuV	Margin dB	Detector	Comment
1		0.1681	18.53	19.76	38.29	65.05	-26.76	QP	
2		0.1771	6.78	19.76	26.54	54.62	-28.08	AVG	
3		0.5596	21.79	19.78	41.57	56.00	-14.43	QP	
4		0.5821	15.47	19.79	35.26	46.00	-10.74	AVG	
5		1.4146	14.47	19.80	34.27	56.00	-21.73	QP	
6		1.6351	9.04	19.82	28.86	46.00	-17.14	AVG	
7		2.6296	13.51	19.84	33.35	56.00	-22.65	QP	
8		2.7106	7.48	19.84	27.32	46.00	-18.68	AVG	
9		4.6276	12.68	19.90	32.58	56.00	-23.42	QP	
10		5.6356	6.21	19.93	26.14	50.00	-23.86	AVG	
11		14.9146	9.52	20.56	30.08	60.00	-29.92	QP	
12		16.6156	1.47	20.65	22.12	50.00	-27.88	AVG	

Note: Pre-Scan all mode, Thus record worse case mode result in this report.



4.2. Radiated Emission Measurement

4.2.1. Block Diagram of Test Setup



4.2.2. Measuring Standard

EN IEC 61000-6-3:2021 (EN 55032:2015+A11:2020)

4.2.3. Radiated Emission Limits

All emanations from a class device or system, including any network of conductors and apparatus connected thereto, shall not exceed the level of field strengths specified below:

FREQUENCY (MHz)	DISTANCE (Meters)	FIELD STRENGTHS LIMIT (dB μ V/m)
30 ~ 230	3	40
230 ~ 1000	3	47

- Note: (1) The smaller limit shall apply at the combination point between two frequency bands.
(2) Distance refers to the distance in meters between the measuring instrument antenna and the closed point of any part of the EUT.

4.2.4. EUT Configuration on Test

The EN 55011 regulations test method must be used to find the maximum emission during radiated emission measurement.

4.2.5. Operating Condition of EUT

4.2.5.1. Turn on the power.

4.2.5.2. Let the EUT work in test mode 1, mode 2 and measure it.



4.2.6. Test Procedure

The EUT is placed on a turntable, which is 0.8 meter high above the ground. The turntable can rotate 360 degrees to determine the position of the maximum emission level. The EUT is set 3 meters away from the receiving antenna, which is mounted on an antenna tower. The antenna can be moved up and down from 1 to 4 meters to find out the maximum emission level. By-log antenna (calibrated by Dipole Antenna) is used as a receiving antenna. Both horizontal and vertical polarization of the antenna is set on test.

The bandwidth of the Receiver is set at 120kHz.

All the scanning waveform is in next page.

4.2.7. Test Results

PASS.


The frequency range from 30MHz to 1000MHz is investigated.

The scanning waveforms is in the next page.





Test Model	IPC3619-3K-TRUMPF	Test Mode	Mode 1
Environmental Conditions	22.3°C, 53.6% RH	Detector Function	Quasi-peak
Pol	Vertical	Distance	3m
Test Engineer	Terence Tang	Test Voltage	DC 24V



	Freq	Reading	CabLos	Antfac	Measured	Limit	Over	Remark
	MHz	dBuV	dB	dB/m	dBuV/m	dBuV/m	dB	
1	107.51	10.36	0.68	12.48	23.52	40.00	-16.48	QP
2	161.47	15.25	0.75	8.71	24.71	40.00	-15.29	QP
3	215.27	18.06	0.95	11.05	30.06	40.00	-9.94	QP
4	315.48	10.32	1.09	13.27	24.68	47.00	-22.32	QP
5	400.43	8.59	1.20	15.07	24.86	47.00	-22.14	QP
6	651.94	6.21	1.58	18.64	26.43	47.00	-20.57	QP


Note: 1. All readings are Quasi-peak values.

2. Measured= Reading + Antenna Factor + Cable Loss

3. The emission that are 20db below the official limit are not reported



Test Model	IPC3619-3K-TRUMPF	Test Mode	Mode 1
Environmental Conditions	22.3℃, 53.6% RH	Detector Function	Quasi-peak
Pol	Horizontal	Distance	3m
Test Engineer	Terence Tang	Test Voltage	DC 24V



	Freq	Reading	CabLos	Antfac	Measured	Limit	Over	Remark
	MHz	dBuV	dB	dB/m	dBuV/m	dBuV/m	dB	
1	119.86	16.43	0.64	10.51	27.58	40.00	-12.42	QP
2	162.61	16.46	0.86	8.75	26.07	40.00	-13.93	QP
3	216.78	22.33	0.88	11.10	34.31	40.00	-5.69	QP
4	364.26	14.51	1.14	14.46	30.11	47.00	-16.89	QP
5	425.03	14.29	1.16	15.49	30.94	47.00	-16.06	QP
6	651.94	6.41	1.58	18.64	26.63	47.00	-20.37	QP

Note: 1. All readings are Quasi-peak values.


2. Measured= Reading + Antenna Factor + Cable Loss

3. The emission that are 20db below the official limit are not reported



4.3. ElectrostaTic Discharge Immunity Test

4.3.1. Block Diagram of Test Setup



4.3.2. Test Standard

EN IEC 61000-6-2:2019 (EN 61000-4-2: 2009,
Severity Level: 3 / Air Discharge: ±8KV, Level: 3 / Contact Discharge: ±4KV)

4.3.3. Severity Levels and Performance Criterion

4.3.3.1. Severity level

Level	Test Voltage Contact Discharge (KV)	Test Voltage Air Discharge (KV)
1.	±2	±2
2.	±4	±4
3.	±6	±8
4.	±8	±15
X	Special	Special

4.3.3.2. Performance Criterion: **B**

4.3.4.EUT Configuration on Test

The configuration of EUT is listed in Section 4.3.1.

4.3.5.Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 4.2.5. Except the test set up replaced by Section 4.3.1.



4.3.6. Test Procedure

4.3.6.1. Air Discharge

This test is done on a non-conductive surface. The round discharge tip of the discharge electrode shall be approached as fast as possible to touch the EUT. After each discharge, the discharge electrode shall be removed from the EUT. The generator is then re-triggered for a new single discharge and repeated 10 times for each pre-selected test point. This procedure shall be repeated until all the air discharge completed

4.3.6.2. Contact Discharge

All the procedure shall be same as Section 4.3.1. Except that the tip of the discharge electrode shall touch the EUT before the discharge switch is operated.

4.3.6.3. Indirect Discharge For Horizontal Coupling Plane

At least 10 single discharges (in the most sensitive polarity) shall be applied at the front edge of each HCP opposite the center point of each unit (if applicable) of the EUT and 0.1m from the front of the EUT. The long axis of the discharge electrode shall be in the plane of the HCP and perpendicular to its front edge during the discharge.

4.3.6.4. Indirect Discharge For Vertical Coupling Plane

At least 10 single discharge (in the most sensitive polarity) shall be applied to the center of one vertical edge of the coupling plane. The coupling plane, of dimensions 0.5m X 0.5m, is placed parallel to, and positioned at a distance of 0.1m from the EUT. Discharges shall be applied to the coupling plane, with this plane in sufficient different positions that the four faces of the EUT are completely illuminated.

4.3.7. Test Results

PASS.

Please refer to the following pages



Electrostatic Discharge Test Results


Standard	☐ IEC 61000-4-2 ☒ EN 61000-4-2		
Applicant	Shanghai Panelmate Electronics Co., Ltd.		
EUT	Industrial Operation Panel PC	Temperature	23.2℃
M/N	IPC3619-3K-TRUMPF	Humidity	53.6%
Criterion	B	Pressure	1021mbar
Test Mode	Mode 1	Test Engineer	Hy Luo

Air Discharge							
Test points	Test Levels			Results			
	± 2KV	± 4KV	± 8KV	Passed	FAIL	Performance Criterion	
Front	☒	☒	☒	☒	☐	☐ A	☒ B
Back	☒	☒	☒	☒	☐	☐ A	☒ B
Left	☒	☒	☒	☒	☐	☐ A	☒ B
Right	☒	☒	☒	☒	☐	☐ A	☒ B
Top	☒	☒	☒	☒	☐	☐ A	☒ B
Bottom	☒	☒	☒	☒	☐	☐ A	☒ B
Contact Discharge							
Test Points	Test Levels		Results				
	± 2 KV	±4 KV	Passed	Fail	Performance Criterion		
Front	☒	☒	☒	☐	☐ A	☒ B	
Back	☒	☒	☒	☐	☐ A	☒ B	
Left	☒	☒	☒	☐	☐ A	☒ B	
Right	☒	☒	☒	☐	☐ A	☒ B	
Top	☒	☒	☒	☐	☐ A	☒ B	
Bottom	☒	☒	☒	☐	☐ A	☒ B	
Discharge To Horizontal Coupling Plane							
Side of EUT	Test Levels		Results				
	± 2 KV	± 4 KV	Passed	Fail	Performance Criterion		
Front	☒	☒	☒	☐	☐ A	☒ B	
Back	☒	☒	☒	☐	☐ A	☒ B	
Left	☒	☒	☒	☐	☐ A	☒ B	
Right	☒	☒	☒	☐	☐ A	☒ B	
Discharge To Vertical Coupling Plane							
Side of EUT	Test Levels		Results				
	± 2 KV	± 4 kV	Passed	Fail	Performance Criterion		
Front	☒	☒	☒	☐	☐ A	☒ B	
Back	☒	☒	☒	☐	☐ A	☒ B	
Left	☒	☒	☒	☐	☐ A	☒ B	
Right	☒	☒	☒	☐	☐ A	☒ B	



4.4. RF Field Strength Susceptibility Test

4.4.1. Block Diagram of Test



4.4.2. Test Standard

EN IEC 61000-6-2:2019

(EN 61000-4-3: 2006+A2: 2010 Severity Level 3: 10V / m; Level 2: 3V/m;)



4.4.3. Severity Levels and Performance Criterion

4.4.3.1. Severity Levels

Level	Field Strength V/m
1.	1
2.	3
3.	10
X.	Special

4.4.3.2. Performance Criterion: A

4.4.4. EUT Configuration on Test

The configuration of the EUT is same as Section 4.4.1.

4.4.5. Operating Condition of EUT

Same as radiated emission measurement, which is listed in Section 4.3.4, except the test setup replaced as Section 4.4.1.

4.4.6. Test Procedure

The EUT are placed on a table, which is 0.8 meter high above the ground. The EUT is set 3 meters away from the transmitting antenna, which is mounted on an antenna tower. Both horizontal and vertical polarization of the antenna is set on test. Each of the four sides of the EUT must be faced this transmitting antenna and measured individually.

In order to judge the EUT performance, a CCD Recording is used to monitor its screen.

All the scanning conditions are as following:

Condition of Test	Remark
1. Fielded Strength	10V/m (Severity Level 3)
2. Radiated Signal	Unmodulated
3. Scanning Frequency	80-1GHz
4. Sweep time of radiated	0.0015 Decade/s
5. Dwell Time	3 Sec.
6. Fielded Strength	3V/m (Severity Level 2)
7. Radiated Signal	Unmodulated
8. Scanning Frequency	1.4-6.0GHz
9. Sweep time of radiated	0.0015 Decade/s
Dwell Time	3 Sec.

4.4.7. Test Results

PASS.

Please refer to the following page.



RF Field Strength Susceptibility Test Results

Standard	☐ IEC 61000-4-3 ☒ EN 61000-4-3		
Applicant	Shanghai Panelmate Electronics Co., Ltd.		
EUT	Industrial Operation Panel PC	Temperature	23.2℃
M/N	IPC3619-3K-TRUMPF	Humidity	53.5%
Test Mode	Mode 1	Criterion	A
Field Strength	10V/m	Field Strength	80 MHz to1.0 GHz
	3 V/m		1.4 GHz to6.0 GHz
Test Engineer	Hy Luo		
Modulation	☐ None ☐ Pulse ☒ AM 1KHz 80%		
Steps	1%		

	Horizontal	Vertical
Front	PASS	PASS
Right	PASS	PASS
Rear	PASS	PASS
Left	PASS	PASS


Note:





4.5. Electrical Fast Transient/Burst Immunity Test

4.5.1. Block Diagram of Test Setup



4.5.2. Test Standard

EN IEC 61000-6-2:2019 (EN 61000-4-4: 2012, Level 3: 1KV)

4.5.3. Severity Levels and Performance Criterion

4.5.3.1. Severity level

Open Circuit Output Test Voltage $\pm 10\%$		
Level	On Power Supply Lines	On I/O (Input/Output) Signal data and control lines
1.	0.5 KV	0.25 KV
2.	1 KV	0.5 KV
3.	2 KV	1 KV
4.	4 KV	2 KV
X	Special	Special

4.5.3.2. Performance Criterion: B

4.5.4. EUT Configuration on Test

The configuration of EUT is listed in Section 3

4.5.5. Operating Condition of EUT

4.5.5.1. Setup the EUT as shown in Section 4.5.1.

4.5.5.2. Turn on the power of all equipments.

4.5.5.3. Let the EUT work in test Mode and measure it.



4.5.6. Test Procedure

The EUT is put on the table, which is 0.8 meter high above the ground. This reference ground plane shall project beyond the EUT by at least 0.1m on all sides and the minimum distance between EUT and all other conductive structure, except the ground plane beneath the EUT, shall be more than 0.5m.

4.5.6.1. For input and output DC power ports:

The EUT is connected to the power mains by using a coupling device, which couples the EFT interference signal to DC power lines. Both polarities of the test voltage should be applied during compliance test and the duration of the test is 2 mins.

5.5.6.2. For signal lines and control lines ports:

The EUT is connected to the power mains by using a coupling device, which couples the EFT interference signal to signal lines. Both polarities of the test voltage should be applied during compliance test and the duration of the test is 1 mins.

4.5.7. Test Results

PASS.

Please refer to the following page.



Electrical Fast Transient/Burst Test Results

Standard	☐ IEC 61000-4-4 ☒ EN 61000-4-4		
Applicant	Shanghai Panelmate Electronics Co., Ltd.		
EUT	Gas Relay	Temperature	24.6°C
M/N	IPC3619-3K-TRUMPF	Humidity	53.6%
Test Mode	Mode 1	Criterion	B
Test Engineer	Hy Luo		


Line	Test Voltage	Result (+)	Result (-)
P	1KV	PASS	PASS
N	1KV	PASS	PASS
PE			
P,N	1KV	PASS	PASS
P,PE			
N,PE			
P,N,PE			
Signal Line			
I/O Cable	0.5KV	PASS	PASS

Note: a: P indicates the positive polarity of the power port, N indicates the negative polarity of the power port.



4.6. Surge Immunity Test

4.6.1. Block Diagram of Test Setup



4.6.2. Test Standard

EN IEC 61000-6-2:2019 (EN 61000-4-5: 2014+A1: 2017, Severity Level: Line to Line: Level 2, 1.0KV, Line to Earth: Level 3, 2.0KV)

4.6.3. Severity Levels and Performance Criterion

4.6.3.1. Severity level

Severity Level	Open-Circuit Test Voltage (KV)
1	0.5
2	1.0
3	2.0
4	4.0
*	Special

4.6.3.2. Performance Criterion: B

4.6.4. EUT Configuration on Test

The configuration of EUT is listed in Section 3

4.6.5. Operating Condition of EUT

4.6.5.1. Setup the EUT as shown in Section 4.6.1.

4.6.5.2. Turn on the power of all equipments.

4.6.5.3. Let the EUT work in test Mode and measure it.



4.6.6. Test Procedure

4.6.6.1. Set up the EUT and test generator as shown on Section 4.6.1.

4.6.6.2. For line to line coupling mode, provide a 1.0 KV 1.2/50us voltage surge (at open-circuit condition) and 8/20us current surge to EUT selected points. For I/O port coupling mode, provide a 0.5kv 10/700us voltage surge to EUT selected points.

4.6.6.3. At least 5 positive and 5 negative (polarity) tests with a maximum 1/min repetition rate are conducted during test.

4.6.6.4. Different phase angles are done individually.

4.6.6.5. Record the EUT operating situation during compliance test and decide the EUT immunity criterion for above each test.

4.6.7. Test Results

PASS.

Please refer to the following page.





Surge Immunity Test Result

Standard	☐ IEC 61000-4-5 ☒ EN 61000-4-5		
Applicant	Shanghai Panelmate Electronics Co., Ltd.		
EUT	Gas Relay	Temperature	24.4℃
M/N	IPC3619-3K-TRUMPF	Humidity	53.5%
Test Mode	Mode 1	Criterion	B
Test Engineer	Hy Luo		

Location	Polarity	Number of Pulse	Pulse Voltage (KV)	Result
P-N	+	/	1.0	PASS
	-	/	1.0	PASS
P-PE				
N-PE				
Signal Line				
I/O Cable	+	/	0.5	PASS
	-	/	0.5	PASS

Note


a: P indicates the positive polarity of the power port, N indicates the negative polarity of the power port.





4.7. Injected Currents Susceptibility Test

4.7.1. Block Diagram of Test Setup



4.7.2. Test Standard

EN 61000-6-2: 2007 (EN 61000-4-6:2014+AC:2015 , Severity Level: Level 3, (0.15MHz ~ 80MHz)

4.7.3. Severity Levels and Performance Criterion

4.7.3.1. Severity level

Level	Field Strength (V)
1	1
2	3
3	10
X	Special

4.7.3.2. Performance Criterion: **A**

4.7.4. EUT Configuration on Test

The configuration of EUT is listed in Section 3

4.7.5. Operating Condition of EUT

4.7.5.1. Setup the EUT as shown in Section 4.7.1.

4.7.5.2. Turn on the power of all equipments.

4.7.5.3. Let the EUT work in test Mode and measure it.



4.7.6. Test Procedure

- 4.7.6.1. Set up the EUT, CDN and test generators as shown on Section 4.7.1.
- 4.7.6.2. Let the EUT work in test mode and measure it.
- 4.7.6.3. The EUT are placed on an insulating support 0.1m high above a ground reference plane. CDN (coupling and decoupling device) is placed on the ground plane about 0.3m from EUT. Cables between CDN and EUT are as short as possible, and their height above the ground reference plane shall be between 30 and 50 mm (where possible).
- 4.7.6.4. The disturbance signal described below is injected to EUT through CDN.
- 4.7.6.5. The EUT operates within its operational mode(s) under intended climatic conditions after power on.
- 4.7.6.6. The frequency range is swept from 150kHz to 80MHz using 3V signal level, and with the disturbance signal 80% amplitude modulated with a 1kHz sine wave.
- 4.7.6.7. The rate of sweep shall not exceed 1.5×10^{-3} decades/s. where the frequency is swept incrementally; the step size shall not exceed 1% of the start and thereafter 1% of the preceding frequency value.
- 4.7.6.8. Recording the EUT operating situation during compliance testing and decide the EUT immunity criterion.

4.7.7. Test Results

PASS.

Please refer to the following page.



Injected Currents Susceptibility Test Results

Standard	☐ IEC 61000-4-6 ☒ EN 61000-4-6		
Applicant	Shanghai Panelmate Electronics Co., Ltd.		
EUT	Industrial Operation Panel PC	Temperature	22.4°C
M/N	IPC3619-3K-TRUMPF	Humidity	52.1%
Test Mode	Mode 1	Criterion	A
Test Engineer	Hy Luo		


Frequency Range (MHz)	Injected Position	Strength (Unmodulated)	Criterion	Result
0.15 ~ 80	DC Mains	10V	A	PASS
0.15 ~ 80	I/O Cable	10V	A	PASS

Note:



4.8. Magnetic Field Susceptibility Test

4.8.1. Block Diagram of Test Setup



4.8.2. Test Standard

EN IEC 61000-6-2:2019

(EN 61000-4-8: 2010, Severity Level: Level 4, 30A / m)

4.8.3. Severity Levels and Performance Criterion

4.8.3.1. Severity Levels

Level	Field Strength A/m
1	1
2	3
3	10
4	30
5	100
X	Special

4.8.3.2. Performance Criterion: A

4.8.4. EUT Configuration on Test

The configuration of the EUT is same as Section 4.8.1

4.8.5. Test Procedure

The EUT is placed in the middle of a induction coil (1*1m), under which is a 1*1*0.1m (high) table, this small table is also placed on a larger table, 0.8 m above the ground. Both horizontal and vertical polarization of the induction coil is set on test, so that each side of the EUT is affected by the magnetic field. Also can reach the same aim by change the position of the EUT.



4.8.6. Test Results

PASS.

Please refer to the following page.





Magnetic Field Immunity Test Result

Standard	☐ IEC 61000-4-8 ☒ EN 61000-4-8		
Applicant	Shanghai Panelmate Electronics Co., Ltd.		
EUT	Industrial Operation Panel PC	Temperature	24.7°C
M/N	IPC3619-3K-TRUMPF	Humidity	53.1%
Test Mode	Mode 1	Criterion	A
Test Engineer	Hy Luo		

Test Level (A/M)	Testing Duration	Coil Orientation	Criterion	Result
30	5 mins	X	A	PASS
30	5 mins	Y	A	PASS
30	5 mins	Z	A	PASS


Note:



5. PHOTOGRAPHS OF TEST SETUP



Test Setup Photo of Power Line Conducted Measurement



Test Setup Photo of Radiated Measurement (30MHz~1GHz)



Test Setup Photo of Electrostatic Discharge Test




Photo of Power Line Electrical Fast Transient/Burst Test & Surge Immunity Test



Test Setup Photo of Power Line Injected Currents Susceptibility Test



Test Setup Photo of Magnetic Field Immunity Test



Test Setup Photo of RF Field Strength Susceptibility Test



6. EXTERNAL AND INTERNAL PHOTOS OF THE EUT



Fig. 1



Fig. 2



Fig. 3



Fig. 4






Fig. 5




Fig. 6



Fig. 7




Fig. 8




Fig. 9




Fig. 10



Fig. 11




Fig. 12




Fig. 13

-----THE END OF TEST REPORT-----